

File: 94M3197

27th April 2005

Mr Gary Jackson,
Technical & Business Development Manager
Xypex Australia
PO Box 255
Lavington NSW 2641



Dear Gary,

Subject: Submission for RTA acceptance of Xypex products as concrete admixtures

Reference: 1. Meetings of 7.12.2004 and 16.2.2005
2. Correspondence dated: 13.12.2004 – Xypex to RTA
21.12.2004 – RTA to Xypex
23.2.2005 – Xypex to RTA
7.4.2005 – RTA to Xypex
19.4.2005 – Xypex to RTA

You are advised that I have no issues with Xypex Admix C-1000NF and Xypex Admix C-5000 being used as concrete admixtures on RTA funded works.

The information provided indicates that these Xypex admixtures would be classified according to AS 1478.1 as special purpose chemical admixtures for reducing permeability of concrete, mortar and grout in accordance with Appendix F, and conforming to Type SN special purpose normal setting admixture, as evidenced from the NATA accredited test reports Xypex has provided to the RTA.

Yours sincerely

A handwritten signature in blue ink that reads "Gregory J. Forster".

Gregory J Forster
Manager, Bridge Specification & Rehabilitation
RTA Bridge Section

